



Textilní zkušební ústav, s.p.

TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.
(TEXTILE TESTING INSTITUTE)
CERTIFICATION BODY FOR THE CERTIFICATION OF PRODUCTS
CEJL 480/12, ZÁBRDOVICE, 602 00 BRNO, CZECH REPUBLIC

issues

to the client: **GAPA MB, s.r.o., Svatovítská 217, 293 01 Mladá Boleslav III, Czech Republic**
ID: 40767795

TESTIMONIAL

No.: 23 - 013

this Testimonial confirms that the product:

Cleaning entrance mat Alba

textile floor covering

material composition - cut pile: 100 % polyamide; backing – polyvinylchloride
total thickness: 7,5 mm; total mass: 3 450 g.m⁻²

complies with the requirements of the standard:

- **EN 13501-1:2018 Fire classification of construction products and building elements – Part 1: Classification using test data from reaction to fire tests (Art. 9.2, 9.4, 12.5, 12.9.2, Table 2)**
Testing was carried out according to the standards:
 - **EN ISO 11925-2** Reaction to fire tests – Ignitability of building products subjected to direct impingement of flame – Part 2: Single-flame source test
 - **EN ISO 9239-1** Reaction to fire tests for floorings – Part 1: Determination of the burning behaviour using a radiant heat source

Table: Evaluated parameters and classification

Testing method	Parameter	Requirement class C_n – s1	Value identified	Evaluation
EN ISO 11925-2 exposure – 15 s	Flame spread F _s	art. 12.5 F _s ≤ 150 mm (20 s)	Flame didn't spread more than 150 mm	S
EN ISO 9239-1	Critical flux (kW.m ⁻²)	art. 12.5 ≥ 4,5 kW.m ⁻²	≥ 4,5	S
	Smoke (%.minute)	art. 12.9.2 ≤ 750 % . minute	≤ 750	S

Legend: S - Satisfy

Classification according to the reaction to fire: **C_n – s1**

This Testimonial has been issued on the basis of the application No. COV/23/023 of 12.01.2023. The base for this Testimonial is the Certificate of constancy of performance No. 1658-CPR-3043 of 15.08.2018, issued by the notified body No. 1658 TFI Aachen, Germany.

Testimonial was issued: Brno: 01.03.2023
Validity up to: 31.03.2025

Issued by:

Tomková
Ing. Lenka Tomková
Certification Department

